



Bristol Kendall Fire Department

FIRE PREVENTION BUREAU

103 East Beaver Street
Yorkville, IL 60560-1704
Phone: 630 553-6186 Ext. 119
Fax: 630 553-1482



PUBLIC EVENT FOOD VENDOR INSPECTION REPORT

Date: _____ Vendor Name: _____ Event: _____

- No open flames under the tents. Grills shall be located outside of tents.
- Fire extinguishers shall be hung and have current tags.
- Extension cords shall be limited and properly sized and rated. Frayed, cut cords are unacceptable.
- All LPG cylinders shall be secured.
- Only approved LPG connectors shall be used. Only connected cylinders and 1 additional tank is permitted.
- Properly secure all signs, banners and displays.
- Grills shall be separated from the public. Discarded coals shall be soaked and properly disposed of.
- Maintain proper exiting and clear aisles throughout the tent.
- Maintain clearance of paper products and other combustible material from heat producing appliances.
- Tents shall be properly secured to the ground. Sake caps shall be used and loose rope shall be wrapped around stakes to prevent tripping.
- Tents shall be flame retardant and have appropriate ratings.
- Trash shall not be piled up under the tents. Trash removal to the proper containers shall be conducted on a regular or as needed basis.

- _____
- _____
- _____
- _____
- _____

Approved Not Approved

BKFD Fire Marshall Date Vendor Representative