

PROTECT YOUR BUSINESSES & 1ST RESPONDERS

Code Objectives for 2021

Regular Fire Sprinkler Testing is Required by the International Fire Code

Chapter 9, Fire Protection Systems of the 2018 International Fire Code requires water based fire protection systems to be inspected, tested and maintained at regular intervals in accordance with NFPA 25: Standard for the Inspection, Testing and Maintenance code objectives for 2021 of Water-Based Fire Protection Systems.


Regular testing is also required through the Illinois Office of the State Fire Marshal's adoption of NFPA 101: Life Safety Code, Section 9.11.1 (2015 edition). All automatic fire sprinkler systems, stand-pipe systems and fire pumps must be inspected and maintained in accordance with NFPA 25.

Any company must be licensed by the State Fire Marshal and anyone testing a fire sprinkler system, standpipe or fire pump must be a **NICET II trained individual or trained through a Dept of Labor Apprentice Program**. Illinois state law, 225ILCS 317/15 (h), requires a copy of all fire sprinkler system inspection reports to be submitted to local fire officials having jurisdiction.

Are you checking these items before work begins? Stop any job violating this state law and/or call the state fire marshal.



Fire Inspection Specialist Bob Kleinheinz of the Lake Zurich Fire Protection District and President of the Northern Illinois Fire Inspectors Association



See below for more information, training classes and code support:

