



Waller County Fire Marshal's Office

Mobile Food Truck

Project Name: _____ Permit Number: _____

Date: _____

Appliances

- | | | | |
|---|---|-----|--|
| Y | N | N/A | Are the appliances within the perimeter of the hood a minimum of 6"? |
| Y | N | N/A | Are the deep fat fryers a minimum of 16" away from an open flame? |
| Y | N | N/A | Are the fuel fired appliances compliant? |
| Y | N | N/A | Are the electrical appliances compliant? |

Hood Suppression System

- | | | | |
|---|---|-----|---|
| Y | N | N/A | Is there an approved vent hood suppression system? |
| Y | N | N/A | Does the vent hood suppression system have a current certification tag? |

Compressed Gas Cylinders

- | | | | |
|---|---|-----|---|
| Y | N | N/A | Do gas cylinders have a current DOT certification? |
| Y | N | N/A | Are cylinders secured properly? |
| Y | N | N/A | Are cylinders protected from physical damage? |
| Y | N | N/A | Are cylinders, fittings, hoses and/or piping free of physical damage? |

Generator

- | | | | |
|---|---|-----|---|
| Y | N | N/A | Is the generator compliant? |
| Y | N | N/A | Is the generator stored & secured properly? |
| Y | N | N/A | Are the fuels stored properly? |
| Y | N | N/A | Are electrical cords/wiring compliant? |

Fire Extinguishers

- | | | | |
|---|---|-----|---|
| Y | N | N/A | Is a Class "K" extinguisher present and have a current certification tag? |
| Y | N | N/A | Do all extinguishers have current certification tags? |
| Y | N | N/A | Are all extinguishers mounted properly? |
| Y | N | N/A | Are all extinguisher brackets free of damage? |

Electrical Systems

- | | | | |
|---|---|-----|--|
| Y | N | N/A | Are electrical systems compliant? |
| Y | N | N/A | Are all electrical outlets in the kitchen area GFCI or GFCI protected? |
| Y | N | N/A | Are approved extension cords present? |
| Y | N | N/A | Are approved multi-plug adaptors present? |

Comments:

Inspector: _____

Contractor Name/License #: _____